



Performance Evaluation of Incremental Conductance and Adaptive HCS MPPT Algorithms for WECS

Ahmed Badawi¹, Hassan Ali¹, I. M. Elzein¹ and Alhareth M. Zyoud²

¹College of Engineering and Technology, University of Doha for Science and Technology, Doha, Qatar

²Department of Electrical and Computer Engineering, Faculty of Engineering, Birzeit University, Birzeit, Ramallah, Palestine

Received 27 Aug. 2023, Revised 19 Feb. 2024, Accepted 11 Mar. 2024, Published 15 Mar. 2024

Abstract: This paper presents a novel Maximum Power Point Tracking (MPPT) algorithm designed for Wind Energy Conversion Systems (WECS) to achieve optimal power extraction (P_{max}). The controllers employed in this study utilize a Direct Power Control (DPC) framework to assess efficiency and performance, particularly under uncertain and rapid variations in wind speed profiles. The research aims to evaluate the effectiveness of the Incremental Conductance (INC) and adaptive Hill-Climbing Search (HCS) algorithms for MPPT in WECS under such conditions. The modeling of the WECS system utilizes a Permanent Magnet Synchronous Generator (PMSG) due to its reliability and robustness. Simulation results demonstrate the significant impact of wind speed on rotor speed and electromagnetic torque, highlighting the proportional relationship between wind speed parameters and power output. The controller performance is evaluated using INC and adaptive HCS, with the latter demonstrating superior efficiency under rapid wind speed changes. Additionally, simulation results show that the INC algorithm exhibits rapid tracking capability in approaching the peak maximum power point. Overall, this study provides valuable insights into the performance of MPPT algorithms in WECS, particularly under varying wind conditions.

Keywords: Incremental conductance algorithm, Hill-climbing search, Wind power, Maximum power point tracking, Permanent magnet synchronous generator, Wind energy conversion system

1. INTRODUCTION

Maximum Power Point Tracking (MPPT) plays a pivotal role in advancing renewable energy systems by maximizing power efficiency within specific operational parameters [1]–[7]. Beyond technical specifications, its efficacy in reducing installation costs and optimizing power quality during operations is well-documented [8]–[13].

In the realm of photovoltaic (PV) modules, the prevalent approach in literature involves the implementation of either "hill climbing" or "incremental conductance" MPPT algorithms due to their simplicity [14], [15]. However, when focusing on innovative MPPT methods, researchers often provide comprehensive summaries of various algorithms [16]–[18]. Critically, research has extensively analyzed the limitations of conventional perturb and observe ($P&O$) algorithms, particularly regarding perturbation step size selection. To address issues like oscillations and convergence speed, variable step-size $P&O$ algorithms have been developed, classified into modified and adaptive $P&O$ categories.

Figure 1 illustrates a classified model of MPPT with respect to total maximum power captured. Types of MPPT include Direct Power Control (DPC) [11], [19]–[21] and

Indirect Power Control (IPC) [1], [2], [8], [11], [22]–[29]. IPC encompasses three approaches: Tip Speed Ratio (TSR), Power Signal Feedback (PSF), and Optimal Torque (OT). The TSR entails an anemometer to measure the speed of the wind as per literature of [30]. The PSF does not require an anemometer but it utilizes turbine blade parameter values. The OT technique does not require an anemometer either, but still necessitates turbine blade parameter values [11], [28], [31]–[33].

The study by [34] proposes a TSR-based controller to adapt to turbine characteristics near the MPP. Equation (1) defines the relationship between output power (P_o) and mechanical power, influenced by generator and converter efficiencies [35], [36]:

$$P_o = \eta_g \eta_c P_{wind} \quad (1)$$

This paper focuses on the Hill-Climbing Search (HCS) and Incremental Conductance (INC) algorithms under the DPC controller to enhance power output by operating the turbine closer to its peak maximum point at the DC link [37], [38]. Equation (2) calculates potential power output P_{out} based




Figure 1. MPPT classified model with respect to total maximum power captured.

on average wind speed [20], [39]:

$$P = 0.5C_p(\lambda, \beta)\rho\pi R^2 V_w^3, \quad (2)$$

where ρ is the density of air, V_w is the velocity of wind, R is the radius of rotor, and C_p is the power coefficient [40].

The power coefficient (C_p) depends on blade tip speed (λ) and blade pitch angle (β). As a result of the Betz limit a wind turbine can ideally and theoretically excerpt 59% maximum wind power [39], [41]–[43]. On the other hand, practically the maximum power that can be produced from the wind turbine is up to 40% [44].

Addressing step-size selection, this research introduces a variable step size technique to balance speed control and step-size application efficiently. By monitoring the operating point's distance from the Maximum Power Point (MPP) and transitioning between optimal curves, this technique selects an appropriate step size, enhancing MPP tracking. However, reliance on wind speed measurement and step-size range limitation constrain its effectiveness. The operational methodology leverages adaptive step-size at each operating point, minimizing oscillations and improving WECS performance.

This paper serves as a benchmark for evaluating INC and adaptive HCS algorithms in terms of convergence speed, oscillations, and efficiency performance.

2. DEVELOPMENT OF HILL CLIMBING SEARCH ALGORITHM

A. Conventional Hill Climbing Search Controller

An algorithm such as HCS is used to observe and control the rotors speed variances and output power where an addition to minor decreases or increases to the rotor speed reference. That would eliminate the necessity wind speeds anemometer. Such a controlling technique is adapted through the P&O algorithm. By consistently varying the rotor speed reference, the system will continuously search, leading to a fluctuation in rotor speed referred to as hysteresis around the peak point. The HCS algorithm utilizes electrical power as its input, which is measured using a




Figure 2. HCS algorithm main principle.

power converter. Realistically, turbine power plays a crucial role during the controlling stage in reaching the peak point. Those powers equally considered when the systems module is at steady-state condition, waiting for a period of time for which the generator powers transient has dissipated [9].

HCS algorithm is a well familiar type of algorithms however it has a very common problem that is weak in reaching MPP of a designated module as well has a slow response time in achieving that. This would result in having a cause of oscillation which leads to losses in power since this algorithm tries to track the MPP and keep trying to reach it without being able to do that and in addition will fluctuate around it [24].

Figure 2 shows HCS principles in tracking the optimal power. Therefore, utilizing the electric power measurement, to estimate the control of the next step. The benefit of over-passing wind turbine data is to guarantee the wind turbine will always operate at its actual MPP, regardless of disparities in the blades external characteristics or other influencing parameters. Though the unique characteristics drive HCS to be the optimal selection in MPPT control at various WECS environments; thus is suitable for wind speed conditions that change slowly [7], [45]. Applying large step size perturbations can enhance the convergence speed but at the negative impact of affecting efficiency which is called a trade-off. Raising the convergence speed also results in more oscillations around the maximum power point, because HCS control keeps oscillating around the peak point, leading to inevitable fluctuations. Conversely, a reduced step size can improve proficiency but may cause the controller to slow down and struggle to track the peak point under dynamic changes in wind factors. The determination of the next perturbation stage in the conventional mechanism is based on the power decrease or increase caused by the previous perturbation step. However, this approach can be misleading if the factors of wind change are not taken into account. In such cases, the change in wind can override the effect of the applied perturbation, leading to an incorrect estimation by the traditional algorithm used in HCS. Consequently, the tracking of the peak point becomes insufficient, and the

Figure 3. Adaptive HCS.

HCS goes downward. From the literature, researchers have proposed using algorithms with variable-step sizes to get to the optimal peak point. Nevertheless, these algorithms have several drawbacks when the operating point is far from MPP. This is primarily caused by the increased extent of the P-V slope as shown in Figure 3.

B. Adaptive HCS-Three Mode

Numerous structures incorporate a primary control unit known as the "master control" that determines the operational mode of the controller, based on wind speed and disparities in wind speed. Such an approach enables the controller to respond accordingly to minor or significant fluctuations in wind speed, or alternatively, maintain a constant rotor speed within a specified dead band limit.

Figure 3 demonstrates adaptive HCS and shows how it reaches the MPP point. The potential for adaptive controllers emerges when they initially operate in a knowledge mode to ascertain the crucial parameters based on a specific wind pattern [7], [46], [47]. Other techniques in the HCS domain are also stated, such as HCS with variable dual step size as well as search recollect algorithms that hold in a specific memory the MPP during the knowledge stage [1], [37], [46]–[52].

C. Hill Climbing Search Adaptive with Power Prediction mode

In the literature Badawi et al 2020 used a novel algorithm that relies on two main mode stages and an intelligent tools which introduced in [9], [10] known as power predicting mode. The introduced algorithm constructed a set of two different modes in detecting the MPP. The main goal of the enhancement is to achieve MPPT in a short time frame. And hence improving the power efficiency of WECS. Note that no iterations calculation is involved and further improving any trade-off as a result of the convergence rate and efficiency [48].

The design and structuring of such algorithm took into consideration how to be simple. It can be applied to different wind speed profiles. Therefore, it can be reached to the

most possible power out of the WECS. A novel algorithm can estimate and predict captured power at wind turbine. Thus, the duty cycle can be applied to the MOSFET to detect the optimal point on the real time without delay [8], [29]. Through the "power prediction technique" a division in the range's references for the wind-speed is actioned for the purpose in getting maximum wind-energy. Through this mechanism, speed of wind identifies the $P_{o(t)}$ established at wind-speed range. The results obtained based on the theory would assure that the proposed enhanced algorithm is notable to be fast and further being efficient as compared to a three mode HCS algorithm. In the power prediction there are five main intervals based on the wind speed data ; interval1: less than 2.5 m/s which is considered a very low wind speed; interval 2: wind speed range that's initiated at (2.5 m/s) and may reach a value of up to (8 m/s); interval 3: The speed of wind range from an initial value of (8 m/s) to a value that may reach (13.3 m/s); interval 4: Range of the speed of wind may take an initial value of (13.3 m/s) up to an incremental value of up to (20.3 m/s) and finally, interval 5: A dedicated wind speed above 20.3 m/s [10].

3. Incremental Conductance algorithm(INC)

INC is a popular algorithm used in tracking the P_{max} . Mostly used extensively because of its ease of use and abilities in tracking the MPP. In addition, the INC algorithm is considered to be utilized as baseline and assumed one of the most standardized references as compared with other novel algorithms.

At the initial start of the process, both the voltage (V) and current (I) determine the WECS output. The changes in the values of the above-mentioned parameters are identified during the calculation in predicting the I and V derivative. Conventional INC algorithms rely on the basis of comparing the current's derivative value (function of voltage) with the instantaneous current of the WECS against voltage. Simply, the MPP is tracked through this technique by incrementing and decrementing an applied reference voltage in accordance with the current operating point of the module [53]. When this method drives the operating point to reach the MPP and hence to conclude the following [54];

$$\frac{dP}{dV} = 0 \tag{3}$$

$$\frac{dP}{dV} = \frac{d(V \cdot I)}{dV} \quad dV = I \frac{dV}{dV} + V \frac{dI}{dV} \tag{4}$$

$$\frac{dI}{dV} = -\frac{I}{V}; \tag{5}$$

where, dI/dV is the current derivative, and I is the instantaneous PV current to voltage.

Further, this method is based on the slope of P-V slope. The P_{max} is reached when it gets a zero slope [55], [56].

Figure 4. INC algorithm flowchart.

The below equations sum up the INC scheme [57]:

$$p = VI \tag{6}$$

$$\frac{dp}{dv} = I + V \frac{di}{dv} \tag{7}$$

Note that when $\frac{dp}{dv} > 0$; $\frac{1}{V} > \frac{di}{dv}$ then in this scenario the voltage must be increased (incremented) and vice versa when $\frac{dp}{dv} < 0$; $\frac{1}{V} < \frac{di}{dv}$ then the voltage must be decreased or (decremented). INC flowchart is represented in Figure 4. In a conventional context of INC scheme, V_{ref} demonstrates a nominal voltage (fixed) that serves for decrementing and incrementing it accordingly based on the system requirements and needs.

4. MODELLING WIND ENERGY CONVERSION SYSTEM BASED ALGORITHMS

The INC algorithm and HCS adaptive algorithm were applied to the WECS using different wind speed profiles with rapid changes based on time. In the first part, the (INC) controller is applied to WECS to obtain P_{max} . The following model represents the main components in the system as exposed in Figure 5. The synchronous generator dynamic model used in this study is a result of two key phases' reference synchronous (direct and the other one is (q) quadrature axis frame. Angle formed angle among those two terms is roughly around 90° degrees. This angle is estimated to be the direction of rotation. The transformation that was utilized in the three-Phase of WECS is illustrated through Equation (8) [58]. Note that another illustration of the inverse transform is reflected in Equation (9) [1], [8], [26], [40], [59]–[64].

$$\begin{pmatrix} F_d \\ F_q \end{pmatrix} = \frac{2}{3} \begin{pmatrix} \sin(\omega t) & \sin(\omega t - \frac{2\pi}{3}) & \sin(\omega t + \frac{2\pi}{3}) \\ \cos(\omega t) & \cos(\omega t - \frac{2\pi}{3}) & \cos(\omega t + \frac{2\pi}{3}) \end{pmatrix} \begin{pmatrix} F_a \\ F_b \\ F_c \end{pmatrix} \tag{8}$$

Figure 5. PMSG wind turbine controller algorithm.

$$\begin{pmatrix} F_d \\ F_q \end{pmatrix} = \frac{2}{3} \begin{pmatrix} \sin(\omega t) & \cos(\omega t) \\ \sin(\omega t - \frac{2\pi}{3}) & \cos(\omega t - \frac{2\pi}{3}) \\ \sin(\omega t + \frac{2\pi}{3}) & \cos(\omega t + \frac{2\pi}{3}) \end{pmatrix} \begin{pmatrix} F_a \\ F_b \\ F_c \end{pmatrix} \tag{9}$$

In the frequency domain, the synchronous generator stator current's d-axis illustrated in Equation (10) and the same applies to q-axis [8].

$$i_{qs} = \frac{V_{qs} - R_s i_{qs} - \omega_r (L_{ds} + L_{ls}) \frac{di_{ds}}{dt}}{s(L_{ds} + L_{qs})} \tag{10}$$

where, i_{ds} is the stator current's d-axis, i_{qs} is the stator current's q axis, $V_{ds}=V_{qs}$ is the stator voltage d axes, ω_r is the angular speed generator, R_s is the stator resistance, L_{ds} is the rotor's flux, and L_{ld} is the self-inductance of stator d axes.

The below equations are setting up the parameters of (L_d) and (L_q) respectively.

$$L_d = L_{ls} + L_{dm} \tag{11}$$

$$L_q = L_{ls} + L_{qm} \tag{12}$$

Knowing that (L_{ls}) is inductance leakage and (L_{dm}) and (L_{qm}) representing in this scheme a magnetized inductance of (d-q-axes) under the influence of a synchronous generator. (L_q)-axis streamlined model in synchronous frame rotor field is addressed in [8].

The calculations of both parameters (ω_r) and (T_e) of PMSG are reflected at Equations (13) and (14) [8];

$$T_e = \frac{3N_p}{2} \omega_r i_{qs} (L_d - L_q) i_{ds} i_{qs} \tag{13}$$

$$\omega_r = \frac{N_p}{JS} (T_e - T_m) \tag{14}$$

where; N_{pp} is the pole pairs number, T_m is the generator mechanical torque, and J is the inertia rotation.

Another set of terms to define are the generator speed

(pu) and synchronous generator torque (pu). As per the rotor of PMSG, an applied torque can be addressed as follows [8], [65], [66].

$$T_m = \frac{0.5 C_p(\lambda) R^2 V_w^3}{\lambda r} \quad (15)$$

At a certain model, note that λ is given a determined value however it is assigned a value of $\neq 0$; such a value is used in wind turbine with a trivial scale.

$$\lambda = \frac{V_{tip}}{V_w} = \frac{\lambda_r}{V_w} \quad (16)$$

From the derived Equations (2) and (16), wind turbine output maximized power is calculated using Equation (17), and constant optimal wind is calculated through Equations (18) and (19).

$$P_{max} = K_{opt} \lambda_{opt}^3 \quad (17)$$

$$K_{opt} = \frac{0.5 C_{pmax} R^5}{\lambda_{opt}^3} \quad (18)$$

$$\lambda_{opt} = \frac{V_{opt}}{R} \quad (19)$$

In exceptional cases formulations, Equation (19) is used to determine λ_{opt} when a condition is applied where the rated speed at both the PMSG and MPPT [8], [24].

Reaching a unity power is a challenging task when it comes to micro controllers where adjusting the module parameters may have a greater effect on the overall performance.

Again, when rated speed was addressed, an assurance is required to ensure this is ideally reaching PMSG along with the power factor (unity stage) and a dc-dc boost converter can be controlled at this case by Duty cycle. The overall advantage is to collect the maximum power available from WECS [67]–[70].

MPPT algorithm drives the integrated module of wind turbine to the highest and ultimate possible speed denoted and addressed as λ_{opt} for every and single wind potential velocity. As a result of the preceding discussions, we may conclude at this stage that, arriving towards the maximum power point will solely be dependable purely on the MPPT scheme control [71], [72].

5. RESULTS AND DISCUSSION

PMSG's induction generator type with WECS model connected with the controller (INCHS) Adaptive to check the performance effectiveness in reaching MPP. The 3-phase output voltage from PMSG is rectified in the sense of converting an AC power waveform to its DC component and then feed it into a predefined controller. To control the voltage (V_{dc}) a dc-dc converter unit is designated for this task. Where a reference voltage (V_{ref}) is supplied by the MPPT controller. This supplied (V_{ref}) is driven to be compared with the (V_{dc}) value and eventually, the final value's reading goes into the controller. Knowing that at this

Figure 6. (Stators I&V), speed of rotor, and WECS electromagnetic torque.

point the controllers' output is checked against the (1) state in a forward step to seek the best switching process of a DC-DC converter, i.e. the "ON/OFF" states.

From Figure 6 the rotor speed increased rapidly because of wind speeds' raised value. The electromagnetic torque is following the rotor speed based on wind speed value.

Stator voltage and current increased dramatically by mean of increasing the mean wind speed data and as mentioned in the literature [10], [24], [29], [56] the mean wind speed has cubic proportional relation with the power value. It can be noticed that the rotor speed value changed due to the wind speed data. The electromagnetic torque has inverse proportional relation with the rotor speed. This is displayed in Figure 6. Stator (I) and (V) raised intensely as per the data of winds' speed and followed the rotor speed behaviour which is due to the proportional relations.

Figure 7 shows a sinusoidal 3-phase power output for the PMSG. It is noticed that the amplitude was increasing due to the fact that the speed of the mean wind is incrementing. The three-phase power value followed the phase angle value, where the phase angle is stable without notable leading/lagging issues. Power factor is symbolized by $PF = \cos(\phi) = 1$ where, in this case the rated power value can be captured from the wind turbine. Therefore,

Figure 7. Three-phase power value of the induction generator between 18.587s and 18.596s power generator.

Figure 8. DC voltage illustration at the incident of 3-phase bridge rectifier (no controller involved).

the system in this situation is considered ready to rectify the power output to utilize the controller on the DC linkage that belongs to the boost DC-DC converter.

Figure 8 represents a rectified signal from the PMSG using the 3-diode rectifier bridge (no controller), where DC voltage value decreased steadily because of decrease wind speed. In addition, the DC voltage raised sharply when the wind speed increases because of cubic proportional relationship taking place through wind speed and power as shown in Equation (1). It can be noticed from the Figure 8 the fluctuation was due to the instability of the applied wind speed. Two different controllers will be applied to this signal to assess how the performance of efficiency acts as the next figures exhibit.

In Figure 9 INC controller had been applied to the rectified signal to reach the optimal peak point and to enhance the efficiency performance.

The result shows fast-tracking capability in detecting the optimal operating point on the power curve, as compared to Figure 8 which shows fluctuations in the captured power. However, the efficiency performance decreased dramatically based on rapid changes in wind speed.

Based on Figure 9, the INC technique has a minimal ripple observed at 7.2 sec, and at 15.3 sec. It can be seen the curve raised roughly at 3.1 sec due to the raised wind speed from 6 m/s to 13 m/s. Here, the incremental technique provided lower oscillation as compared with adaptive HCS. Hence, the INC shows fast tracking capability to reach the optimal point. In the steady-state conditions of the wind speed profile, Incremental and adaptive techniques have

Figure 9. DC voltage after the INC controller.

Figure 10. DC voltage after HCS Adaptive controller.

similar efficiency performance as shown in Figures 8 and 9. However, the adaptive HCS has higher captured power compared to the INC, particularly during the rapid change in wind speed.

In Figure 10, it shows the DC volt signal after applying the adaptive HCS. It can be noticed that the adaptive HCS algorithm with power prediction mode along a rapid response upheld the P_{max} value successfully which is a valuable insight into power efficiency. Adaptive HCS algorithm shows the best efficiency performance under rapid change wind speed. Adaptive HCS at every wind speed value, the operating condition is kept at its optimal point. This is due to the power prediction mode stage with high accuracy as compared to incremental technique. Thus adaptive HCS technique captures P_{max} even during wind speeds' dynamic fluctuations, as shown in Figure 10. Further, adaptive HCS technique has a lower overshoot than the incremental technique from 6-8 seconds and 14-16 seconds through wind speed instabilities.

6. Conclusion

In this study, we have addressed two essential algorithms within control structured techniques for wind turbines, integral to tuning WECS with the unique goal of driving PMSG to optimal efficiency by achieving unity power factor. The INC and adaptive HCS algorithms have demonstrated accurate tracking and detection of the MPP.

Theoretical results confirm that INC exhibits fast tracking capability to reach the MPP, albeit with decreased efficiency performance under rapid changes in wind speed. Conversely, adaptive HCS demonstrates high efficiency and performance in response to rapid changes in wind speed, with enhancements observed in steady-state efficiency.

These findings underscore the importance of algorithm selection and adaptation in optimizing WECS performance under varying wind conditions, contributing to the advancement of renewable energy systems. Further research could explore refinement and integration of these algorithms to enhance overall efficiency and stability in wind energy applications.

References

- [1] M. Monica, P. Sivakumar, S. J. Isac, and K. Ranjitha, "Pmsg based wecs: Control techniques, mppt methods and control strategies for standalone battery integrated system," International Conference on the Applications of Differential Equations in Sciences (NTADES2022), 2022. [Online]. Available: <https://api.semanticscholar.org/CorpusID:247982668>
- [2] C. V. Govinda, S. V. Udhay, C. Rani, Y. Wang, and K. Busawon, "A review on various MPPT techniques for wind energy conversion system," 2018 International Conference on Computation of Power, Energy, Information and Communication (ICCPEIC) conference on computation of power, energy, Information and Communication (ICCPEIC) pp. 310–326, 2018. [Online]. Available: <https://api.semanticscholar.org/CorpusID:53280766>
- [3] M. Premkumar, R. Sowmya, C. Ramakrishnan, P. Jangir, E. H. Houssein, S. Deb, and N. Manoj Kumar, "An efficient and reliable scheduling algorithm for unit commitment scheme in microgrid systems using enhanced mixed integer particle swarm optimizer considering uncertainties," Energy Reports vol. 9, pp. 1029–1053, 2023. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S2352484722026245>
- [4] J. Hussain and M. K. Mishra, "Adaptive maximum power point tracking control algorithm for wind energy conversion systems," IEEE Transactions on Energy Conversion vol. 31, no. 2, pp. 697–705, 2016.
- [5] C. Huang, F. Li, and Z. Jin, "Maximum power point tracking strategy for large-scale wind generation systems considering wind turbine dynamics," IEEE Transactions on Industrial Electronics vol. 62, no. 4, pp. 2530–2539, 2015.
- [6] M. Narayana, G. A. Putrus, M. G. Jovanović, P. S. Leung, and S. P. McDonald, "Generic maximum power point tracking controller for small-scale wind turbines," Renewable Energy vol. 44, pp. 72–79, 2012. [Online]. Available: <https://api.semanticscholar.org/CorpusID:15207256>
- [7] S. M. R. Kazmi, H. Goto, H.-J. Guo, and O. Ichinokura, "A novel algorithm for fast and efficient speed-sensorless maximum power point tracking in wind energy conversion system," IEEE Transactions on Industrial Electronics vol. 58, no. 1, pp. 29–36, 2011.
- [8] A. Badawi, "Maximum power point tracking control scheme for small scale wind turbine," Ph.D. dissertation, International Islamic University Malaysia (IIUM), 2019.
- [9] A. Badawi, N. F. Hasbullah, S. H. Yusof, A. H. A. Hashim, and A. M. Zyoud, "Novel technique for hill climbing search to reach maximum power point tracking," International Journal of Power Electronics and Drive Systems vol. 11, pp. 2019–2029, 2020. [Online]. Available: <https://api.semanticscholar.org/CorpusID:225005618>
- [10] A. Badawi, N. F. Hasbullah, S. H. Yusof, A. H. A. Hashim, S. Khan, and A. M. Zyoud, "Power prediction mode technique for hill climbing search algorithm to reach the maximum power point tracking," 2020 2nd International Conference on Electrical, Control and Instrumentation Engineering (ICECI), pp. 1–7, 2020. [Online]. Available: <https://api.semanticscholar.org/CorpusID:230997525>
- [11] D. Kumar and K. Chatterjee, "A review of conventional and advanced MPPT algorithms for wind energy systems," Renewable and Sustainable Energy Reviews vol. 55, pp. 957–970, 2016. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S1364032115012654>
- [12] E. H. Dursun and A. A. Kulaksiz, "Second-order sliding mode voltage-regulator for improving MPPT efficiency of PMSG-based WECS," International Journal of Electrical Power & Energy Systems vol. 121, p. 106149, 2020. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0142061519339481>
- [13] M. Premkumar, N. Shankar, R. Sowmya, P. Jangir, C. Kumar, L. M. Abualigah, and B. Derebew, "A reliable optimization framework for parameter identification of single-diode solar photovoltaic model using weighted velocity-guided grey wolf optimization algorithm and Lambert-W function," IET Renewable Power Generation 2023. [Online]. Available: <https://api.semanticscholar.org/CorpusID:259633486>
- [14] M. Miyatake, M. Veerachary, F. Toriumi, N. Fujii, and H. Ko, "Maximum power point tracking of multiple photovoltaic arrays: A PSO approach," IEEE Transactions on Aerospace and Electronic Systems vol. 47, no. 1, pp. 367–380, 2011.
- [15] L. Cristaldi, M. Faifer, M. Rossi, and S. Toscani, "An improved model-based maximum power point tracker for photovoltaic panels," IEEE Transactions on Instrumentation and Measurement vol. 63, pp. 63–71, 2014. [Online]. Available: <https://api.semanticscholar.org/CorpusID:35695079>
- [16] H. Li, D. Yang, W. Su, J. Li, and X. Yu, "An overall distribution particle swarm optimization MPPT algorithm for photovoltaic system under partial shading," IEEE Transactions on Industrial Electronics vol. 66, no. 1, pp. 265–275, 2019.
- [17] A. B. M. Elzein, H. Ali, and K. M. A. M. Zyoud, "State of the art perturb and observe MPPT algorithms based wind energy conversion systems: A technology review," Unpublished 2024.
- [18] M. Dhimish, "Assessing MPPT techniques on hot-spotted and partially shaded photovoltaic modules: Comprehensive review based on experimental data," IEEE Transactions on Electron Devices vol. 66, no. 3, pp. 1132–1144, 2019.
- [19] Y. Errami, M. Benchagra, M. Hilal, M. Maarouf, and M. Ouassaid, "Control strategy for PMSG wind farm based on MPPT and direct power control," 2012 International Conference on Multimedia Computing and Systems, pp. 1125–1130, 2012. [Online]. Available: <https://api.semanticscholar.org/CorpusID:16306486>
- [20] J. Singh and M. Ouhrouch, "MPPT control methods in wind energy conversion systems," InTech, Jun. 2011.
- [21] M. Kermadi, S. Mekhilef, Z. Salam, J. Ahmed, and E. M. Berkouk, "Assessment of maximum power point trackers performance using direct and indirect control methods," International Transactions on Electrical Energy Systems vol. 30, 08 2020.
- [22] R. Tiwari, K. Kumar, N. R. Babu, and K. R. Prabhu, "Coordinated mppt and dpc strategies for PMSG based grid connected wind

- energy conversion system, *Energy Procedia* 2018. [Online]. Available: <https://api.semanticscholar.org/CorpusID:115279568>
- [23] M. B. Toriki, M. K. Asy'ari, and A. Musyafa, "Enhanced performance of PMSG in WECS using MPPT - Fuzzy sliding mode control," *Journal Européen des Systemes Automatisés* 2021. [Online]. Available: <https://api.semanticscholar.org/CorpusID:233782872>
- [24] A. Badawi, N. F. Hasbullah, S. H. Yuso A. H. A. Hashim, S. Khan, and A. M. Zyoud, "Paper review: maximum power point tracking for wind energy conversion system 2020 2nd International Conference on Electrical, Control and Instrumentation Engineering (ICECIE) pp. 1–6, 2020. [Online]. Available: <https://api.semanticscholar.org/CorpusID:230994725>
- [25] A. Badawi, H. Ali, N. A. Ismail, P. Ramallah, A. Zyoud, and S. H. Yuso, "Weibull probability distribution based on four years wind speed data using nine numerical methods," *Unpublished*
- [26] J. Baran and A. Jaderko, "An mppt control of a PMSG-based WECS with disturbance compensation and wind speed estimation," *Energies* 2020. [Online]. Available: <https://api.semanticscholar.org/CorpusID:229431810>
- [27] H. H. H. Mousa, A. Youssef, and E. E. M. Mohamed, "State of the art perturb and observe MPPT algorithms based wind energy conversion systems: A technology review," *International Journal of Electrical Power & Energy Systems*, vol. 126, p. 106598, 2021. [Online]. Available: <https://api.semanticscholar.org/CorpusID:228907082>
- [28] R. Maher, A. K. Abdelsalam, Y. G. Dessouky, and A. Nouman, "High performance state-ow based mppt technique for micro WECS," *IET Renewable Power Generation* 2019. [Online]. Available: <https://api.semanticscholar.org/CorpusID:208832514>
- [29] A. Badawi, H. Ali, N. A. Ismail, P. Ramallah, A. Zyoud, and S. H. Yuso, "Wind energy production using novel HCS algorithm to reach MPPT for small-scale wind turbines under rapid change wind speed," *Unpublished*
- [30] G. Hua and Y. Geng, "A novel control strategy of MPPT taking dynamics of wind turbine into account," *2006 37th IEEE Power Electronics Specialists Conference*, 2006, pp. 1–6.
- [31] K. S. M. Raza, H. Goto, H.-J. Guo, and O. Ichinokura, "Maximum power point tracking control and voltage regulation of a dc grid-tied wind energy conversion system based on a novel permanent magnet reluctance generator," *2007 International Conference on Electrical Machines and Systems (ICEMS)*, 2007, pp. 1533–1538.
- [32] I. Buehring and L. Freris, "Control policies for wind-energy conversion systems," *Generation, Transmission and Distribution, IEE Proceedings C*, vol. 128, pp. 253 – 261, 10 1981.
- [33] S. M. R. Kazmi, H. Goto, H.-J. Guo, and O. Ichinokura, "Review and critical analysis of the research papers published till date on maximum power point tracking in wind energy conversion system," in *2010 IEEE Energy Conversion Congress and Exposition*, 2010, pp. 4075–4082.
- [34] A. Mahdi, W. Tang, L. Jiang, and Q. Wu, "A comparative study on variable-speed operations of a wind generation system using vector control," *Renewable Energy and Power Quality Journal*, vol. 1, 04 2010.
- [35] A. Badawi, H. Ali, I. M. Elzein, A. M. Zyoud, and A. Abu-Hudrouss, "Highly efficient pure sine wave inverter using microcontroller for photovoltaic applications," *2023 International Symposium on Networks, Computers and Communications (ISNCC)*, pp. 1–6, 2023. [Online]. Available: <https://api.semanticscholar.org/CorpusID:265484054>
- [36] S. Agrawal, S. Pandya, P. Jangir, K. Kalita, and S. Chakraborty, "A multi-objective thermal exchange optimization model for solving optimal power flow problems in hybrid power systems," *Decision Analytics Journal*, vol. 8, p. 100299, 2023. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S277266222300139X>
- [37] H. Gouabi, A. Hazzab, M. Habbab, M. Rezkallah, and A. Chandra, "Experimental implementation of a novel scheduling algorithm for adaptive and modified po mppt controller using fuzzy logic for WECS," *International Journal of Adaptive Control and Signal Processing*, vol. 35, 06 2021.
- [38] L. Mdakane and M. Kamper, "Simple robust MPPT control for wind energy DC-grid connected systems," *IECON 2019-45th Annual Conference of the IEEE Industrial Electronics Society*, Oct 2019, pp. 2495–2500.
- [39] A. Badawi, "An analytical study for establishment of wind farms in Palestine to reach the optimum electrical energy," 07 2013.
- [40] A. Badawi, N. F. Hasbullah, S. H. Yuso S. Khan, A. H. A. Hashim, A. M. Zyoud, and M. Elamassie, "Evaluation of wind power for electrical energy generation in the mediterranean coast of Palestine for 14 years," *International Journal of Electrical and Computer Engineering (IJECE)* 2019. [Online]. Available: <https://api.semanticscholar.org/CorpusID:208083439>
- [41] A. Badawi, S. Yuso, A. Zyoud, S. Khan, A. Hashim, Y. Uyagut, and M. Ismail, "Data bank: nine numerical methods for determining the parameters of weibull for wind energy generation tested by ve statistical tools," *International Journal of Power Electronics and Drive Systems (IJPEDS)*, vol. 12, p. 1114, 06 2021.
- [42] A. Badawi, N. F. Hasbullah, S. H. Yuso A. H. A. Hashim, and M. Elamassie, "Practical electrical energy production to solve the shortage in electricity in Palestine and pay back period," *International Journal of Electrical and Computer Engineering*, vol. 9, pp. 4610–4616, 2019. [Online]. Available: <https://api.semanticscholar.org/CorpusID:208076671>
- [43] A. Badawi, M. Ouda, A. M. Zyoud, and S. H. Yuso, "The simplest estimation method of weibull probability distribution parameters," *2021 6th IEEE International Conference on Recent Advances and Innovations in Engineering (ICRAIE)*, 6, pp. 1–5, 2021. [Online]. Available: <https://api.semanticscholar.org/CorpusID:246870607>
- [44] L. P. Chamorro and R. E. A. Arndt, "Non-uniform velocity distribution effect on the Betz–Joukowski limit," *Wind Energy*, vol. 16, pp. 279–282, 2013. [Online]. Available: <https://api.semanticscholar.org/CorpusID:120823911>
- [45] S. Kumar, P. Jangir, G. G. Tejani, and M. Premkumar, "A decomposition based multi-objective heat transfer search algorithm for structure optimization," *Knowledge-Based Systems*, vol. 253, p. 109591, 2022. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0950705122008024>
- [46] R. D. Shukla and R. K. Tripathi, "Maximum power extraction schemes & power control in wind energy conversion system,"



- International Journal of Scientific and Engineering Research*, vol. 3, 06 2012.
- [47] J. Singh and M. Ouhrouche, *MPPT control methods in wind energy conversion systems*. InTech, Jun. 2011.
- [48] H. Mousa, A.-R. Youssef, and E. Mohamed, "Study of robust adaptive step-sizes P&O MPPT algorithm for high-inertia wt with direct-driven multiphase pmsg," *International Transactions on Electrical Energy Systems*, 07 2019.
- [49] M. C. Akkaya, A. Polat, and L. T. Ergene, "Mppt based adaptive control algorithm for small scale wind energy conversion systems with pmsg," in *2019 International Aegean Conference on Electrical Machines and Power Electronics (ACEMP) 2019 International Conference on Optimization of Electrical and Electronic Equipment (OPTIM)*, 2019, pp. 517–522.
- [50] Z. Alrowaili, M. Ali, A.-R. Youssef, H. Mousa, A. Ali, G. Abdel-Jaber, M. Ezzeldien, and F. Gami, "Robust adaptive HCS MPPT algorithm-based wind generation system using model reference adaptive control," *Sensors*, vol. 21, 07 2021.
- [51] A. Yesudhas, Y. H. Joo, and S. Lee, "Reference model adaptive control scheme on PMVG-based WECS for MPPT under a real wind speed," *Energies*, vol. 15, p. 3091, 04 2022.
- [52] M. M. Ali, A. Youssef, A. S. Ali, and G. T. Abdel-Jaber, "Variable step size PO MPPT algorithm using model reference adaptive control for optimal power extraction," *International Transactions on Electrical Energy Systems*, 2019. [Online]. Available: <https://api.semanticscholar.org/CorpusID:201235921>
- [53] R. I. Putri, S. Wibowo, and M. Rifa'i, "Maximum power point tracking for photovoltaic using incremental conductance method," *Energy Procedia*, vol. 68, pp. 22–30, 2015, 2nd International Conference on Sustainable Energy Engineering and Application (ICSEEA) 2014 Sustainable Energy for Green Mobility. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S1876610215005342>
- [54] M. H. Ibrahim, S. P. Ang, M. N. Dani, M. I. Rahman, R. Petra, and S. M. Sulthan, "Optimizing step-size of perturb & observe and incremental conductance MPPT techniques using PSO for grid-tied pv system," *IEEE Access*, vol. 11, pp. 13 079–13 090, 2023.
- [55] M. N. Ali, K. Mahmoud, M. Lehtonen, and M. M. F. Darwish, "An efficient fuzzy-logic based variable-step incremental conductance MPPT method for grid-connected PV systems," *IEEE Access*, vol. 9, pp. 26 420–26 430, 2021.
- [56] A. Badawi, M. Ouda, A. M. Zyoud, and S. H. Yusoff, "Maximum power point tracking controller technique using permanent magnet synchronous generator," *2021 6th IEEE International Conference on Recent Advances and Innovations in Engineering (ICRAIE)*, vol. 6, pp. 1–5, 2021. [Online]. Available: <https://api.semanticscholar.org/CorpusID:246870229>
- [57] T. Eram and P. Chapman, "Comparison of photovoltaic array maximum power point tracking techniques," *Energy Conversion, IEEE Transactions on*, vol. 22, pp. 439 – 449, 07 2007.
- [58] P. Krause, O. Wasynczuk, S. D. Sudhoff, and S. Pekarek, *Analysis of electric machinery and drive systems*, 3rd ed., ser. IEEE Press Series on Power Engineering, P. Krause, O. Wasynczuk, S. Sudhoff, and S. Pekarek, Eds. Nashville, TN: John Wiley & Sons, Aug. 2013.
- [59] K. Amei, Y. Takayasu, T. Ohji, and M. Sakui, "A maximum power control of wind generator system using a permanent magnet synchronous generator and a boost chopper circuit," *Proceedings of the Power Conversion Conference-Osaka 2002 (Cat. No.02TH8579)*, vol. 3, pp. 1447–1452 vol.3, 2002. [Online]. Available: <https://api.semanticscholar.org/CorpusID:110635579>
- [60] A. Jain, S. Shankar, and V. Vanitha, "Power generation using permanent magnet synchronous generator (PMSG) based variable speed wind energy conversion system (WECS): An overview," *Journal of green engineering*, vol. 7, 2018. [Online]. Available: <https://api.semanticscholar.org/CorpusID:108402216>
- [61] A. Westlake, J. R. Bumby, and E. S. Spooner, "Damping the power-angle oscillations of a permanent-magnet synchronous generator with particular reference to wind turbine applications," 1996.
- [62] A. Badawi, N. Hasbullah, S. Yusoff, S. Khan, A. Hashim, A. Zyoud, and M. Elamassie, "Weibull probability distribution of wind speed for Gaza strip for 10 years," *Applied Mechanics and Materials*, vol. 892, pp. 284–291, 06 2019.
- [63] A. Badawi, N. Hasbullah, S. Yusoff, and A. Hashim, "Energy and power estimation for three different locations in Palestine," *Indonesian Journal of Electrical Engineering and Computer Science*, vol. 14, pp. 1049–1056, 06 2019.
- [64] N. Verma, S. Banerjee, S. Gupta, S. Goyal, and R. Sharma, "PMSG based WECS with MPPT via modified p & o algorithm," in *2019 3rd International Conference on Recent Developments in Control, Automation & Power Engineering (RDCAPE)*, 2019, pp. 646–650.
- [65] P. Sahin, R. Resmi, and V. Vanitha, "Pmsg based standalone wind electric conversion system with mppt," in *2016 International Conference on Emerging Technological Trends (ICETT)*, 2016, pp. 1–5.
- [66] U. H. Khan, Q. Khan, L. Khan, W. Alam, N. Ali, I. Khan, K. S. Nisar, and R. A. Khan, "Mppt control paradigms for PMSG-WECS: A synergistic control strategy with gain-scheduled sliding mode observer," *IEEE Access*, vol. 9, pp. 139 876–139 887, 2021.
- [67] Y. Errami, M. Maaroufi, and M. Ouassaid, "A MPPT vector control of electric network connected wind energy conversion system employing PM synchronous generator," *2013 International Renewable and Sustainable Energy Conference (IRSEC)*, pp. 228–233, 2013. [Online]. Available: <https://api.semanticscholar.org/CorpusID:8330996>
- [68] Y. Errami, M. Hilal, M. Benchagra, M. Maaroufi, and M. Ouassaid, "Nonlinear control of MPPT and grid connected for wind power generation systems based on the PMSG," *2012 International Conference on Multimedia Computing and Systems*, pp. 1055–1060, 2012. [Online]. Available: <https://api.semanticscholar.org/CorpusID:8774171>
- [69] E. Radwan, S. Kamel, L. S. Nasrat, and A. Youssef, "Improved PO MPPT for grid connected wind energy conversion system," *2023 IEEE Conference on Power Electronics and Renewable Energy (CPERE)*, pp. 1–6, 2023. [Online]. Available: <https://api.semanticscholar.org/CorpusID:258641711>
- [70] A. Badawi, S. Kazmi, R. Boby, M. Shah, and K. Matter, "Resonant circuit response for contactless energy transfer under variable pwm," *International Journal of Information and Electronics Engineering*, vol. 7, pp. 41–47, 01 2017.

